

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2021/WZ/ 778

Dated: 27/9/21

FIRE SAFETY CERTIFICATE

Certified that the B.S. International School located at Plot no. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041 comprised of Ground plus two upper floors owned/occupied by Shri Dalip Singh Educational & Welfare Society, A-50, Uday Vihar, Nilothi, Delhi-41 has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2018/2005 dated 31/08/2018. The premises was re-inspected by officer concerned of this department on 13/09/2021 in the presence of Mr. Anoop Shokeen (Manager) of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular. No. 262-362 dated 17/01/2005 and that the building/premises is fit for occupancy class "Educational Building" Group-B, as above with effect from27/9/21..... 2021 for a period of **Three years** subject to the compliance of the conditions mentioned below.

Issued on 27/9/21 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Principal, B.S. International School located at Plot no. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041.
2. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.